

06.02.6758.165.07.193.25. 201

27 July 2025

Dear Sir

AMENDMENT OF TECHNICAL SPECIFICATION (LOT: 04)

References:


A. DEW Ltd Tender no: 06.02.6758.165.07.193.25.2844 Dated 29 June 2025.

1. The subject mentioned technical specification is amended as follows:

Clause No	For	Read
Technical Specification Annex B of serial no: 02	<u>Sea Water Hydrophore System with Pump, Electrical Control Box & necessary accessories.</u> Brand: To be mentioned Model: To be mentioned Tank volume: Min 500 Ltr, 4 bar Material of Tank: Galvanized Steel No of Pumps: 02 sets (01 standby) Pump Capacity: Min 2.0 m3/hr, 4.0 bar Power: 415 V, 3 phase, 50 Hz Accessories: Pressure switches, Level Gauges, Safety Valves, etc. Country of Origin & Manufacturer: EU/USA/UK/Japan/Turkey/S. Korea/China Certification: BV Class Certificate	<u>Sea Water Hydrophore System with Pump, Electrical Control Box & necessary accessories.</u> Brand: To be mentioned Model: To be mentioned Tank volume: Min 200 Ltr , 4 bar Material of Tank: Galvanized Steel No of Pumps: 02 sets (01 standby) Pump Capacity: Min 3.0 m3/hr , 4.0 bar Power: 415 V, 3 phase, 50 Hz Accessories: Pressure switches, Level Gauges, Safety Valves, etc. Country of Origin & Manufacturer: EU/USA/UK/Japan/Turkey/S. Korea/China Certification: BV Class Certificate

2. Forwarded for information and necessary action please.

With regards


MOSTOFA KAMAL
 Commander BN
 For Managing Director

Distribution:

External:

Action:

All concern suppliers

Internal:

GM (P&D), DEW Ltd